

REGARDING SAFE DRINKING WATER

Certificate

No. 162 -----

DATE 02/07/2026

It is certified that an inspection team headed by— *Mr. Jai Kishan Kumar*
(Assistant Chemist) from *P. H. Division Bhagalpur East, Bhagalpur*
inspected the *DAV Public School, Mathurapur, Shivanarayanpur,*
Bhagalpur on *27.06.2026* and found the *DAV Public School,*
Mathurapur, Shivanarayanpur, Bhagalpur has safe drinking water facilities for
the students and members of staff institution as per the norms prescribed by the
Central/State/ U.T Govt.

The above valid for a period of- *One Year (02.07.2026 to 01.07.2027).*

Signature With Seal:-

Name

Designation

Sanjay Kr Paswan

:-Assistant Research Officer

To,

Daav Public School
Mathurapur,
Shivanarayanpur,
Bhagalpur
Bihar
813222

Government Of Bihar

Regional Water Testing Laboratory

Public Health Engineering Department,

Bhagalpur

Name of School :-DAV Public School

Sample Collected By- Lab Staff

Source of Sample- R.O Water

Ref.No. EE-2308 dt-25.06.2026

Date of Sampling - 27.06.2026

PHYSICO-CHEMICAL & BACTERIOLOGICAL TEST REPORT

S.No.	Location				Physico - Chemical and Bacteriological Parameters																Remarks
	Block	Panchayet	Village	Habitation	Name	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO ₃	SO ₄	F	As	Microbial	
1					DAV Public School Mathurapur,Shivnarayanpur,Bhagalpur- 813222 (Bihar)	7.91	0.46	158.1	78.5	41.3	16.5	6.75	27.1	31.7	0.21	2.75	6.8	0.05	NA	Negative	
					Desirable Limit*	6.5-8.5	1.0	-	500	300	75	30	250	200	1.0	45.0	200	1.0	0.01	-	
					Permissible Limit* in absence of alternate source	NR	5.0	-	2000	600	200	100	1000	600	NR	NR	400	1.5	NR	**	

NA=Not Applicable

Memo No....*RL-102*

Copy Forwarded To :1. Executive Engineer, P.H.Division Bhagalpur East, for kind information and necessary action.

Date ...*02/07/2026*

Humar
02/07/26
Lab Incharge(A.R.O)