

REGARDING SAFE DRINKING WATER

Certificate

No. 123

DATE 19/06/2025

It is certified that an inspection team headed by— *Mr. Jai Kishan Kumar*
(Assistant Chemist) from *P. H. Division Bhagalpur East, Bhagalpur*
inspected the *DAV Public School, Mathurapur, Shivanarayanpur,*
Bhagalpur on *14.06.2025* and found the *DAV Public School,*
Mathurapur, Shivanarayanpur, Bhagalpur has safe drinking water facilities for
the students and members of staff institution as per the norms prescribed by the
Central/State/ U.T Govt.

The above valid for a period of- *One Year (19.06.2025 to 18.06.2026)*.

Signature With Seal:-

Name

:- Sanjay Kr. Paswan

Designation

:- Assistant Research Officer



To,

DAV PUBLIC SCHOOL
Mathurapur,
Shivanarayanpur,
Bhagalpur
Bihar
813222



Government Of Bihar

Regional Water Testing Laboratory

Public Health Engineering Department,

Bhagalpur

Ref.No. EE-1852 Dt-12/06/2025

Date of Sampling - 14.06.2025

Name of School :-DAV Public School

Sample Collected By- Lab Staff

Source of Sample- Raw Water

PHYSICO-CHEMICAL & BACTERIOLOGICAL TEST REPORT

S.No.	Location					Physico - Chemical and Bacteriological Parameters															Remarks
	Block	Panchayet	Village	Habitation	Name	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO ₃	SO ₄	F	As	Microbial	
1	DAV Public School Mathurapur,Shivnarayanpur,Bhagalpur- 813222 (Bihar)					7.57	0.36	240.0	120.0	60.5	26.1	12.8	30.1	51.5	0.14	3	6.1	0.18	NA	Negative	
	Desirable Limit*					6.5-8.5	1.0	-	500	300	75	30	250	200	1.0	45.0	200	1.0	0.01	-	
	Permissible Limit* in absence of alternate source					NR	5.0	-	2000	600	200	100	1000	600	NR	NR	400	1.5	NR	**	
NA=Not Applicable																					

NA=Not Applicable

Memo No.... RL - 123

Date 19/06/2025

Copy Forwarded To :1. Executive Engineer, P.H.Division Bhagalpur East, for kind information and necessary action.

Sumax
19/06/25
Lab Incharge(A.R.O)

